

Evidence for Self-Organized Criticality in a Time Series of Electric Power System Blackouts

Benjamin A. Carreras, David E. Newman, Ian Dobson, *Senior Member, IEEE*, and A. Bruce Poole

Abstract—We analyze a 15-year time series of North American electric power transmission system blackouts for evidence of self-organized criticality (SOC). The probability distribution functions of various measures of blackout size have a power tail and rescaled range analysis of the time series shows moderate long-time correlations. Moreover, the same analysis applied to a time series from a sandpile model known to be self-organized critical gives results of the same form. Thus, the blackout data seem consistent with SOC. A qualitative explanation of the complex dynamics observed in electric power system blackouts is suggested.

Index Terms—Blackouts, complex systems, power system security, reliability, risk analysis, time series.

I. INTRODUCTION

ELECTRIC power transmission networks are complex systems that are commonly run near their operational limits. Major cascading disturbances or blackouts of these transmission systems have serious consequences. Individually, these blackouts can be attributed to specific causes, such as lightning strikes, ice storms, equipment failure, shorts resulting from untrimmed trees, excessive customer-load demand, or unusual operating conditions. However, an exclusive focus on these individual causes can overlook the global dynamics of a complex system in which repeated major disruptions from a wide variety of sources are a virtual certainty. We analyze a time series of blackouts to probe the nature of these complex system dynamics.

Manuscript received May 28, 2002; revised March 18, 2004. Part of this work was coordinated by the Consortium for Electric Reliability Technology Solutions and was funded by the Assistant Secretary for Energy Efficiency and Renewable Energy, Office of Power Technologies, Transmission Reliability Program of the U.S. Department of Energy under Contract DE-AC05-00OR22725 and Contract DE-A1099EE35075 with the National Science Foundation. Part of this work was carried out at Oak Ridge National Laboratory, managed by UT-Battelle, LLC, for the U.S. Department of Energy under Contract DE-AC05-00OR22725. The work of I. Dobson and D.E. Newman was supported in part by the National Science Foundation under Grant ECS-0085711, Grant ECS-0085647, Grant ECS-0214369 and Grant ECS0216053. This paper was recommended by Associate Editor I. A. Hiskens.

B. A. Carreras is with Oak Ridge National Laboratory, Oak Ridge, TN 37831 USA (e-mail: carrerasba@ornl.gov).

D. E. Newman is with the Physics Department, University of Alaska, Fairbanks, AK 99775 USA (e-mail: ffdn@uaf.edu).

I. Dobson is with the Electrical and Computer Engineering Department, University of Wisconsin, Madison, WI 53706 USA (e-mail: dobson@engr.wisc.edu).

A. B. Poole is with the Federal Energy Regulatory Commission, Washington, DC 20426 USA (e-mail: dobson@engr.wisc.edu).

Digital Object Identifier 10.1109/TCSI.2004.834513

The North American Electrical Reliability Council (NERC) has a documented list summarizing major blackouts¹ of the North American power grid [1]. They are of diverse magnitude and of varying causes. It is not clear how complete this data is, but it is the best-documented source that we have found for blackouts in the North American power transmission system. An initial analysis of these data [6] over a period of five years suggested that self-organized criticality (SOC) [2], [3], [23] may govern the complex dynamics of these blackouts. Here, we further examine this hypothesis [7], [13] by extending the analysis to 15 years. These extended data allow us to develop improved statistics and give us longer time scales to explore. We compare the results to the same types of analysis of time sequences generated by a sandpile model known to be SOC. The similarity of the results is quite striking and is suggestive of the possible role that SOC plays in power system blackouts. A plausible qualitative explanation of SOC in power system blackouts is outlined in Section VI.

As an introduction to the concept, an SOC system is one in which the nonlinear dynamics in the presence of perturbations organize the overall average system state near, but not at, the state that is marginal to major disruptions. SOC systems are characterized by a spectrum of spatial and temporal scales of the disruptions that exist in remarkably similar forms in a wide variety of physical systems [2], [3], [23]. In these systems, the probability of occurrence of large disruptive events decreases as a power function of the event size. This is in contrast to many conventional systems in which this probability decays exponentially with event size.

It is apparent that large blackouts are rarer than small blackouts, but how much rarer are they? Fig. 1 shows the probability distribution of blackout size from the North American blackout data that is discussed in detail in Section II. Fig. 2 shows a probability distribution of number of line outages obtained from a blackout model that represents cascading failure and complex dynamics [11]. These data suggest a power law relationship between blackout probability and blackout size. For comparison, Fig. 2 also shows the binomial probability distribution of number of line outages and its exponential tail that would be obtained if the line outages were independent. Blackout risk is the product of blackout probability and blackout cost. Here, we assume that blackout cost is roughly proportional to blackout size, although larger blackouts may well have costs (especially

¹The NERC data arise from government incident reporting requirements. The thresholds for the report of an incident include uncontrolled loss of 300 MW or more of firm system load for more than 15 min from a single incident, load shedding of 100 MW or more implemented under emergency operational policy, loss of electric service to more than 50 000 customers for 1 h or more, and other criteria detailed in the U.S. Department of Energy form EIA-417.




Fig. 1. Log-log plot of PDF of the number of customers unserved comparing the total data set with the data excluding the weather related events.




Fig. 2. Log-log plot of PDF of number of line outages from blackout model compared with binomial random variable with exponential tail.

indirect costs) that increase faster than linearly. In the case of the exponential tail, large blackouts become rarer much faster than blackout costs increase, so that the risk of large blackouts is negligible. However, in the case of a power law tail, the larger blackouts can become rarer at a similar rate as costs increase, and then the risk of large blackouts is comparable to, or even exceeding, the risk of small blackouts [11]. Thus power laws in blackout size distributions significantly affect the risk of large blackouts and the evidence for power laws in real blackout data that we address in this paper is pertinent. Standard probabilistic

techniques that assume independence between events imply exponential tails and are not applicable to systems that exhibit power tails.

Large blackouts are typically caused by long, intricate cascading sequences of rare events. Dependencies between the first few events can be assessed for a subset of the most likely or anticipated events and this type of analysis is certainly useful in addressing a part of the problem (e.g., [26]). However, this combinatorial analysis gets overwhelmed and becomes infeasible for long sequences of events or for the huge number of all possible rare events and interactions, many of which are unanticipated, that cascade to cause large blackouts. One aim of global complex systems analysis of power system blackouts is to provide new insights and approaches that could address these challenges. As a first step toward this aim, this paper analyzes observed blackout data and suggests one way to understand the origin of the dynamics and distribution of power system blackouts. Indeed, we suggest that the slow, opposing forces of load increase and network upgrade in response to blackouts shape the system operating margins so that cascading blackouts occur with a frequency governed by a power law relationship between blackout probability and blackout size. Moreover, we discuss the dynamical dependencies and correlations between blackouts in the NERC data.

II. TIME SERIES OF BLACKOUT DATA

We have analyzed 15 years of data for North America from 1984 to 1998 that is publicly available from NERC [1]. There are 427 blackouts in 15 years and 28.5 blackouts per year. The average period of time between blackouts is 12.8 days. The blackouts are distributed over the 15 years in an irregular manner. We have detected no evidence of systematic changes in the number of blackouts or periodic or quasi-periodic behavior. However, it is difficult to determine long term trends or periodic behavior in just 15 years of data. We constructed time series from the NERC data with the resolution of a day for the number of blackouts and for three different measures of the blackout size. The length of the time record is 5479 days. The three measures of blackout size are:

- 1) energy unserved (MW·h);
- 2) amount of power lost (MW);
- 3) number of customers affected.

Energy unserved was estimated from the NERC data by multiplying the power lost by the restoration time.

III. ANALYSIS OF BLACKOUT TIME SERIES

In order to gain an understanding of the dynamics of a system from analysis of a time series, one must employ a variety of tools beyond basic statistical analysis. Among other measures which should be employed, the tails of the probability distribution function (PDF) should be investigated for normality and frequency spectra should be viewed in order to begin to look at dependencies in the time domain. The time domain is particularly important as the system dynamics are expressed in time. Periodicities and long-time correlations must both be examined and compared to systems with known dynamics. We will present details of the analysis of the PDFs later; however, the




Fig. 3. Complementary cumulative frequency of the number of customers unserved.

first striking characteristic of the data is the power law tail of these PDFs. This power law tail is shown in Fig. 1, where we have plotted the PDF of the number of customers unserved for all events (the squares) on a log–log plot. The PDF falls off with a power of approximately -1.7 , which implies a divergent variance. The PDF is clearly not a distribution with exponential tails. In this paper, the PDFs are noncumulative PDFs obtained by binning the data.² An alternative way to estimate the distribution is to plot the number of blackouts with more than n customers unserved against n to give the complementary cumulative frequency shown in Fig. 3. The empirical data in Fig. 3 falls off with a power of approximately -0.8 (all tail points considered) or -0.7 (last seven tail points neglected due to sparse data). The relationship for an exact distribution is that a power law exponent α in a PDF yields a power law exponent of $\alpha - 1$ in the corresponding complementary cumulative frequency. Thus the power law exponents obtained from Figs. 1 and 3 are consistent.

Looking in the time domain, a time series is said to have long-range dependence if its autocorrelation function falls off asymptotically as a power law. This type of dependence is difficult to determine because noise tends to dominate the signal for long time lags. One way to address this problem is the rescaled range (R/S) statistics proposed by Mandelbrot and Wallis [24] and based on a previous hydrological analysis by Hurst [21]. The R/S statistics consider blocks of m successive points in the integrated time series and measure how fast the range of the blocks grows as m increases. The calculation of the R/S statistics is further described in the Appendix.

It can be shown that in the case of a time series X with an autocorrelation function that has a power law tail, the R/S

²The bins are chosen to require a minimum number of points per bin. The minimum number of points per bin is reduced when the weather-related blackouts are excluded.

TABLE I
HURST PARAMETER H FROM R/S ANALYSIS OF BLACKOUT SIZE TIME SERIES

	H
Events	0.62
Power lost	0.59
Customers	0.57
MWh	0.53

statistic scales proportionally to m^H , where H is the Hurst exponent. Thus, H is the asymptotic slope on a log–log plot of the R/S statistic versus the time lag. If $1 > H > 0.5$, there are long-range time correlations, for $0.5 > H > 0$, the series has long-range anticorrelations, and if $H = 1.0$, the process is deterministic. Uncorrelated noise corresponds to $H = 0.5$. A constant H parameter over a long range of time-lag values is consistent with self-similarity of the signal in this range [32] and with an autocorrelation function that decays as a power of the time lag with exponent $2 - 2H$.

We have determined the long-range correlations in the 15 year blackout time series using the R/S method. The time series has 5479 days and 427 blackouts. The calculated Hurst exponents [21] for the different measures of blackout size are shown in Table I. The H values are obtained by fitting over time lags between 100 and 3000 days. In this range, the behavior of the R/S statistic is power like. The values of H obtained for all the time series are close to 0.6. This seems to indicate that they are all equally correlated over the long range. These values of H are somewhat lower than the previously obtained values [6], but still significantly above 0.5. Note that the “events” in the time series are the events that have produced a blackout and not all the events that occurred. The latter are supposed to be random ($H = 0.5$); however, the events that produce a blackout may indeed have moderate correlations because they depend on the state of the system.

A method of testing the independence of the triggering events has been suggested by Boffetta *et al.* [4]. They evaluated the times between events (waiting times) and argued that the PDF of the waiting times should have an exponential tail. Such is clearly the case for the waiting times of sandpile avalanches (Fig. 4). In the case of waiting times between blackouts, we also have observed the same exponential dependence of the PDF tail (Fig. 5). This observation is confirmed in [13]. This strengthens the contention that the apparent correlations in the events come from SOC-like dynamics within the power system rather than from the events driving the power system dynamics.

Examining the R/S results in more detail, Fig. 6 shows the R/S statistic for the time series of the number of customers affected by blackouts. The average period of time without blackouts is 12.8 days, hence, in looking over time lags of this order we typically find either one blackout or none. For the shorter time lags less than 50 days, we are unable to get information on correlations between blackouts because the time intervals are too short to contain several blackouts. We see a correlation between absence of blackouts, and because these time intervals tend to only contain absences of blackouts, we see H close to 1 (trivially deterministic). For time lags above 50 days, the R/S shows a power behavior and gives a correct determination of blackout correlation. The R/S calculation is sensitive to this change in regime




Fig. 4. Distribution of waiting times between avalanches in a sandpile for two values of the probability of adding grains of sand.




Fig. 5. PDF of the waiting times between blackouts.

and there is an obvious change of behavior for time intervals around 50 days. An alternative method of determining correlations is the scaled window variance method. We do not use the scaled window variance method in this paper because in this method, the correlations between absences of blackouts skew the correlations between blackouts at larger time lags [7].

IV. EFFECT OF WEATHER

Approximately half of the blackouts (212 blackouts) are characterized as weather related in the NERC data. In attempting to extract a possible periodicity related to seasonal weather, we consider separately the time series of all blackouts and the time series of blackouts that are not weather related. An important




Fig. 6. R/S for the number of customers affected by blackouts.

TABLE II
HURST PARAMETER H FOR MEASURES OF BLACKOUT SIZE COMPARING ALL DATA WITH DATA EXCLUDING BLACKOUTS TRIGGERED BY WEATHER

	H all events	H nonweather events
Events	0.62	0.62
Power lost	0.59	0.64
Customers	0.57	0.58
MWh	0.53	0.57

issue in studying long-range dependencies is the possible presence of periodicities. Both R/S analysis and spectral analysis of this data do not show any clear periodicity. However, since the weather related events may play an important role in the blackouts, one may suspect seasonal periodicities. However, the data combines both summer and winter peaking regions of North America. Because of the limited amount of data, it is not possible to separate the blackouts by geographical location and redo the analysis. What we have done is to reanalyze the data excluding the blackouts triggered by weather related events. The results are summarized in Table II. As can be seen, the exclusion of the blackouts triggered by weather related events does not significantly change the value of H . When looking solely at the blackouts triggered by weather related events, the value of H is closer to 0.5 (random events), although the available data is too sparse to be sure of the significance of this result.

Another question to consider is the effect of excluding the weather related events on the PDF. We have recalculated the PDF for all the measures of blackout size when the weather related events are not included. The PDFs obtained are the same within the numerical accuracy of this calculation. This is illustrated in Fig. 1, where we have plotted the PDFs of the number of customers unserved for all events and for the nonweather related events. Therefore, for both long-range dependencies and structure of the PDF, the blackouts triggered by weather events do not show any particular properties that distinguish them from the

other blackouts. Therefore, both the long time correlations and the PDFs of the blackout sizes remain consistent with SOC-like dynamics.

In addition to weather effects, one might expect spatial structure of the grid to have an effect on the dynamics. However, analysis of the NERC data by Chen *et al.* in [13] suggests that similar results are obtained when data for the eastern and western North American power systems is analyzed separately. Since the eastern and western power systems have different characteristics, this interesting result tends to support the notion that there are some underlying common principles for the system dynamics.

V. COMPARISON TO SOC SANDPILE MODEL

The issue of determining whether power system blackouts are governed by SOC is a difficult one. There are no unequivocal determining criteria. One approach is to compare characteristic measures of the power system to those obtained from a known SOC system. The prototypical model of a SOC system is a one-dimensional idealized running sandpile [22]. The mass of the sandpile is increased by adding grains of sand at random locations. However, if the height at a given location exceeds a threshold, then grains of sand topple downhill. The topplings cascade in avalanches that transport sand to the edge of the sandpile, where the sand is removed. In the running sandpile, the addition of sand is on average balanced by the loss of sand at the edges and there is a globally quasi-steady state or dynamic equilibrium close to the critical profile that is given by the angle of repose. There are avalanches of all sizes and the PDF of the avalanche sizes has a power law tail. The particular form of the sandpile model used here is explained in [25] and the sandpile length used in the present calculations is $L = 800$. We are, of course, not claiming that the running sandpile is a model for power system blackouts. We only use the running sandpile as a black box to produce a time series of avalanches characteristic of a SOC system.

It is convenient to assume that every time iteration of the sandpile corresponds to one day. When an avalanche starts, we integrate over the number of sites affected and the number of steps taken and assign them to a single day. Thus we construct a time series of the avalanche sizes. The sandpile model has a free parameter p_0 , which is the probability of a grain of sand being added at a location. p_0 is chosen so that the average frequency of avalanches is the same as the average frequency of blackouts.

In evaluating the long-range time dependence of the blackouts, we use the rescaled range or R/S [24] technique described earlier. As stated before, the R/S technique is useful in determining the existence of a power law tail in the autocorrelation function and calculating the exponent of the decay of the tail (see Appendix for details). The same R/S analysis used for the blackout time series is applied to the avalanche time series. Fig. 7 shows the R/S statistic for the time series of avalanche sizes from the sandpile and for the time series of power lost by the blackouts. The similarity between the two curves is remarkable. A similarly good match of the R/S statistics between the blackout and sandpile time series is obtained for the other measures of blackout size.




Fig. 7. R/S for avalanche sizes in a running sandpile compared to R/S for power lost in blackouts.




Fig. 8. Rescaled PDF of energy unserved during blackouts superimposed on the PDF of the avalanche size in the running sandpile.

Fig. 8 shows the PDF of the avalanche sizes from the sandpile data together with the rescaled PDF of the energy unserved from the blackout data. The resemblance between the two distributions is again remarkable. The rescaling is necessary because of the different units used to measure avalanche size and blackout size. That is, we assume a transformation of the form

$$P(X) = \lambda F\left(\frac{X}{\lambda}\right). \tag{1}$$

X is the variable that we are considering, $P(X)$ is the corresponding PDF, and λ is the rescaling parameter. If the transformation (1) works, F is the universal function that describes the

PDF for the different parameters. Transformation (1) is used to overlay the sandpile and blackout PDFs.

We can consider PDFs of the other measures of blackout size and use transformation (1) to plot each of these PDFs with the sandpile avalanche size PDF. In all cases, the agreement is very good. Of course, the rescaling parameter differs for each measure of blackout size. The exponents obtained for these PDFs tails are between -1.3 and -2 . These exponents imply divergence of the variance, one of the characteristic features of systems with SOC dynamics. In fact, divergence of the variance is a general feature of systems near criticality. This comparison of the PDFs of the measures of blackout and avalanche sizes is useful in evaluating the possible errors in the determination of the power law decay exponent of the PDFs. One can see that for the large size events where the statistics are sparse, there may be deviations from the curve. These deviations can influence the computed value of the exponent, but they are probably of little significance for the present comparisons.

VI. POSSIBLE EXPLANATION OF POWER SYSTEM SOC

To motivate comparisons between power system blackout data and SOC sandpile data, we suggest a qualitative description of the structure and effects in a large-scale electric power transmission system which could give rise to SOC dynamics. The power system contains many components such as generators, transmission lines, transformers and substations. Each component experiences a certain loading each day and when all the components are considered together, they experience some pattern or vector of loadings. The pattern of component loadings is determined by the power system operating policy and is driven by the aggregated customer loads at substations. The power system operating policy includes short term actions such as generator dispatch as well as longer term actions such as improvements in procedures and planned outages for maintenance. The operating policy seeks to satisfy the customer loads at least cost. The aggregated customer load has daily and seasonal cycles and a slow secular increase of about 2% per year.

Events are either the limiting of a component loading to a maximum or the zeroing of the component loading if that component trips or fails. Events occur with a probability that depends on the component loading. For example, the probability of relay misoperation [13] or transformer failure generally increases with loading. Another example of an event could be an operator redispatching to limit power flow on a transmission line to its thermal rating and this could be modeled as probability zero when below the thermal rating of the line and probability one when above the thermal rating. Each event is a limiting or zeroing of load in a component and causes a redistribution of power flow in the network and hence a discrete increase in the loading of other system components. Thus events can cascade. If a cascade of events includes limiting or zeroing the load at substations, it is a blackout. A stressed power system experiencing an event must either redistribute load satisfactorily or shed some load at substations in a blackout. A cascade of events leading to

blackout usually occurs on a time scale of minutes to hours and is completed in less than one day.

It is customary for utility engineers to make prodigious efforts to avoid blackouts and especially to avoid repeated blackouts with similar causes. These engineering responses to a blackout occur on a range of time scales longer than one day. Responses include repair of damaged equipment, more frequent maintenance, changes in operating policy away from the specific conditions causing the blackout, installing new equipment to increase system capacity, and adjusting or adding system alarms or controls. The responses reduce the probability of events in components related to the blackout, either by lowering their probabilities directly or by reducing component loading by increasing component capacity or by transferring some of the loading to other components. The responses are directed toward the components involved in causing the blackout. Thus the probability of a similar blackout occurring is reduced, at least until load growth degrades the improvements made. There are similar, but less intense responses to unrealized threats to system security such as near misses and simulated blackouts.

The pattern or vector of component loadings may be thought of as a system state. Maximum component loadings are driven up by the slow increase in customer loads via the operating policy. High loadings increase the chances of cascading events and blackouts. The loadings of components involved in the blackout are reduced or relaxed by the engineering responses to security threats and blackouts. However, the loadings of some components not involved in the blackout may increase. These opposing forces driving the component loadings up and relaxing the component loadings are a reflection of the standard tradeoff between satisfying customer loads economically and security. The opposing forces apply over a range of time scales. We suggest that the opposing forces, together with the underlying growth in customer load and diversity give rise to a dynamic equilibrium and conjecture that this dynamic equilibrium could be SOC-like. It is important to note that this type of system organizes itself to an operating point near to but not at a critical value. This could make the system intrinsically vulnerable to cascading failures from unexpected causes as the repair and remediation steps taken to prevent a known failure mode are part of the system dynamics.

We briefly indicate the roughly analogous structure and effects in an idealized sand pile model. Events are the toppling of sand and cascading events are avalanches. The system state is a vector of maximum gradients at all the locations in the sand pile. The driving force is the addition of sand, which tends to increase the maximum gradient, and the relaxing force is gravity, which topples the sand and reduces the maximum gradient. SOC is a dynamic equilibrium in which avalanches of all sizes occur and in which there are long time correlations between avalanches. The rough analogy between the sand pile and the power system is shown in Table III. There are also some distinctions between the two systems. In the sand pile, the avalanches are coincident with the relaxation of high gradients. In the power system, each blackout occurs on fast time scale (less than one day), but the knowledge of which components caused the blackout determines which component loadings are relaxed both immediately after the blackout and for some time after the blackout.

TABLE III
ANALOGY BETWEEN POWER SYSTEM AND SAND PILE

	power system	sand pile
system state	loading pattern	gradient profile
driving force	customer load	addition of sand
relaxing force	response to blackout	gravity
event	limit flow or trip	sand topples

VII. CONCLUSION

We have calculated long time correlations and PDFs for several measurements of blackout size in the North American power transmission grid from 1984 to 1998. These long time correlations and PDFs seem consistent with long-range time dependencies and PDFs for avalanche sizes in a running sandpile known to be SOC. That is, for these statistics, the blackout size time series seem indistinguishable from the sandpile avalanche size time series. This similarity suggests that SOC-like dynamics may play an important role in the global complex dynamics of power systems.

We have outlined a possible qualitative explanation of the complex dynamics in a power system which proposes some of the opposing forces that could give rise to a dynamic equilibrium with some properties of SOC. The opposing forces are, roughly speaking, a slow increase in loading (and system aging) weakening the system and the engineering responses to blackouts strengthening parts of the system. Here we are suggesting that the engineering and operating policies of the system are important and integral parts of the system long-term complex dynamics. Carlson and Doyle have introduced a theory of highly optimized tolerance (HOT) that describes power law behavior in a number of engineered or otherwise optimized applications [5]. After this paper was first submitted, Stubna and Fowler [33] published an alternative view based on HOT of the origin of the power law in the NERC data.³

The PDFs of the measures of blackout size have power tails with exponents ranging from -1.3 to -2 and therefore have divergent variances. Thus large blackouts are much more frequent than might be expected. In particular, the application of traditional risk evaluation methods can underestimate the risk of large blackouts. R/S analysis of the blackout time series shows moderate ($H \approx 0.6$) long time correlations for several measures of blackout size. Excluding the weather related blackouts from the time series has little effect on the results. The exponential tail of the PDF of the times between blackouts supports the contention that the correlations between blackouts are due to the power system global dynamics rather than correlations in the events that trigger blackouts.

³To apply HOT to the power system, it is assumed that blackouts propagate one dimensionally [33] and that this propagation is limited by finite resources that are engineered to be optimally distributed to act as barriers to the propagation [5]. The one-dimensional assumption implies that the blackout size in a local region is inversely proportional to the local resources. Minimizing a blackout cost proportional to blackout size subject to a fixed sum of resources leads to a probability distribution of blackout sizes with an asymptotic power tail and two free parameters. The asymptotic power tail exponent is exactly -1 and this value follows from the one dimensional assumption. The free parameters can be varied to fit the NERC data for both MW lost and customers disconnected. Moreover, [33] shows that a better fit to both these data sets can be achieved by modifying HOT to allow some misallocation of resources.

The strength of our conclusions is naturally somewhat limited by the short time period (15 years) of the available blackout data and the consequent limited resolution of the statistics. To further understand the mechanisms governing the complex dynamics of power system blackouts, modeling of the power system is indicated. There is substantial progress in modeling and analyzing the approach inspired by SOC outlined in Section VI [8]–[12], [17] and in modeling blackouts and cascading failure from other perspectives [14]–[16], [18]–[20], [27], [29]–[31], [34].

If the dynamics of blackouts are confirmed to have some characteristics of SOC, this would open up possibilities for monitoring statistical precursors of large blackouts or controlling the power system to modify the expected distribution of blackout sizes [11]. Moreover, it would suggest the need to revisit the traditional risk analysis based on random variables with exponential tails since these complex systems have statistics with power tails.

APPENDIX

Consider the time series $X = \{X_t; t = 1, 2, \dots, n\}$. We construct the series $Y = \{Y_t; t = 1, 2, \dots, n\}$ that is the original series integrated in time: $Y_t = \sum_{s=0}^t X_s$. For the series Y and for each $m = 1, 2, \dots, n$ a new series $Y^{(m)} = \{Y_u^{(m)}; u = 1, 2, \dots, n/m\}$ is generated. The elements of the series $Y^{(m)}$ are blocks of m elements of Y so that $Y_u = \{Y_{um-m+1}, \dots, Y_{um}\}$. We then calculate the range R_m^i and standard deviation S_m^i within each of the n/m blocks of m elements of $Y^{(m)}$, and compute for each block R_m^i/S_m^i . The R/S statistic as a function of the time lag m is then the average $(m/n) \sum_{i=1}^{n/m} R_m^i/S_m^i$.

ACKNOWLEDGMENT

The authors would like to thank J. S. Thorp and R. Weron for useful discussions. I. Dobson would like to thank H-D. Chiang and the School of Electrical Engineering at Cornell University for their generous hospitality during a sabbatical leave.

REFERENCES

- [1] Information on Blackouts in North America [Online]. Available: <http://www.nerc.com/~dawg/database.html>
- [2] P. Bak, C. Tang, and K. Wiesenfeld, "Self-organized criticality: An explanation of $1/f$ noise," *Phys. Rev. Lett.*, vol. 59, pp. 381–4, 1987.
- [3] P. Bak, *How Nature Works: The Science of Self-Organized Criticality*. New York: Copernicus, 1996.
- [4] G. Boffetta, V. Carbone, P. Guliani, P. Veltri, and A. Vulpiani, "Power laws in solar flares: Self-organized criticality or turbulence?," *Phys. Rev. Lett.*, vol. 83, pp. 4662–4665, 1999.
- [5] J. M. Carlson and J. Doyle, "Highly optimized tolerance: A mechanism for power laws in designed systems," *Phys. Rev. E*, vol. 60, pp. 1412–1427, 1999.
- [6] B. A. Carreras, D. E. Newman, I. Dobson, and A. B. Poole, "Initial evidence for self-organized criticality in electric power blackouts," in *Proc. 33rd Hawaii Int. Conf. System Sciences*, Maui, HI, Jan. 2000.
- [7] —, "Evidence for self organized criticality in electric power system blackouts," in *Proc. 34th Hawaii Int. Conf. System Sciences*, Maui, HI, Jan. 2001.
- [8] B. A. Carreras, V. E. Lynch, M. L. Sachtjen, I. Dobson, and D. E. Newman, "Modeling blackout dynamics in power transmission networks with simple structure," in *Proc. 34th Hawaii Int. Conf. System Sciences*, Maui, HI, Jan. 2001.

- [9] B. A. Carreras, V. E. Lynch, I. Dobson, and D. E. Newman, "Dynamics, criticality and self-organization in a model for blackouts in power transmission systems," in *Proc. 35th Hawaii Int. Conf. System Sciences*, Maui, HI, Jan. 2002.
- [10] —, "Critical points and transitions in an electric power transmission model for cascading failure blackouts," *Chaos*, vol. 12, no. 4, pp. 985–994, 2002.
- [11] B. A. Carreras, V. E. Lynch, D. E. Newman, and I. Dobson, "Blackout mitigation assessment in power transmission systems," in *Proc. 36th Hawaii Int. Conf. System Sciences*, Maui, HI, Jan. 2003.
- [12] B. A. Carreras, V. E. Lynch, I. Dobson, and D. E. Newman, "Complex dynamics of blackouts in power transmission systems," *Chaos*, to be published.
- [13] J. Chen, J. S. Thorp, and M. Parashar, "Analysis of electric power system disturbance data," in *Proc. 34th Hawaii Int. Conf. System Sciences*, Maui, HI, Jan. 2001.
- [14] J. Chen and J. S. Thorp, "A reliability study of transmission system protection via a hidden failure DC load flow model," in *Proc. 5th Int. Conf. Power System Management and Control*, 2002, pp. 384–389.
- [15] J. Chen, J. S. Thorp, and I. Dobson, Power Systems Engineering Research Center, Cornell Univ., Ithaca, NY, PSERC Rep. 03–09 [Online]. Available: <http://www.pserc.org>, 2003.
- [16] C. L. DeMarco, "A phase transition model for cascading network failure," *IEEE Control Syst. Mag.*, pp. 40–51, Dec. 2001.
- [17] I. Dobson, B. A. Carreras, V. E. Lynch, and D. E. Newman, "An initial model for complex dynamics in electric power system blackouts," in *Proc. 35th Hawaii Int. Conf. System Sciences*, Maui, HI, Jan. 2001.
- [18] I. Dobson, J. Chen, J. S. Thorp, B. A. Carreras, and D. E. Newman, "Examining criticality of blackouts in power system models with cascading events," in *Proc. 35th Hawaii Int. Conf. System Sciences*, Maui, HI, Jan. 2002.
- [19] I. Dobson, B. A. Carreras, and D. E. Newman, "A probabilistic loading-dependent model of cascading failure and possible implications for blackouts," in *Proc. 36th Hawaii Int. Conf. System Sciences*, Maui, HI, Jan. 2003.
- [20] —, "A branching process approximation to cascading load-dependent system failure," in *Proc. 37th Hawaii Int. Conf. System Sciences*, Maui, HI, Jan. 2004.
- [21] H. E. Hurst, "Long-term storage capacity of reservoirs," *Trans. Amer. Soc. Civil Eng.*, vol. 116, p. 770, 1951.
- [22] T. Hwa and M. Kardar, "Avalanches, hydrodynamics, and discharge events in models of sandpiles," *Phys. Rev. A*, vol. 45, no. 10, pp. 7002–7023, 1992.
- [23] H. J. Jensen, *Self-Organized Criticality*. Cambridge, U.K.: Cambridge Univ. Press, 1998.
- [24] B. B. Mandelbrot and J. R. Wallis, "Noah, Joseph, and operational hydrology," *Water Resources Res.*, vol. 4, pp. 909–918, 1969.
- [25] D. E. Newman, B. A. Carreras, P. H. Diamond, and T. S. Hahm, "The dynamics of marginality and self-organized criticality as a paradigm turbulent transport," *Phys. Plasmas*, pt. 2, vol. 3, no. 5, pp. 1858–1866, May 1996.
- [26] M. Ni, J. D. McCalley, V. Vittal, and T. Tayyib, "Online risk-based security assessment," *IEEE Trans. Power Syst.*, vol. 18, pp. 258–265, Feb. 2003.
- [27] P. A. Parrilo, S. Lall, F. Paganini, G. C. Verghese, B. C. Lesieutre, and J. E. Marsden, "Model reduction for analysis of cascading failures in power systems," in *Proc. Amer. Control Conf.*, vol. 6, 1999, pp. 4208–4212.
- [28] D. L. Pepyne, C. G. Panayiotou, C. G. Cassandras, and Y.-C. Ho, "Vulnerability assessment and allocation of protection resources in power systems," in *Proc. Amer. Control Conf.*, vol. 6, 2001, pp. 4705–4710.
- [29] M. A. Rios, D. S. Kirschen, D. Jawayeera, D. P. Nedic, and R. N. Allan, "Value of security: Modeling time-dependent phenomena and weather conditions," *IEEE Trans. Power Systems*, vol. 17, pp. 543–548, Aug. 2002.
- [30] S. Roy, C. Asavathiratham, B. C. Lesieutre, and G. C. Verghese, "Network models: Growth, dynamics, and failure," in *Proc. 34th Hawaii Int. Conf. System Sciences*, Maui, HI, Jan. 2001.
- [31] M. L. Sachtjen, B. A. Carreras, and V. E. Lynch, "Disturbances in a power transmission system," *Phys. Rev. E*, vol. 61, no. 5, pp. 4877–4882, 2000.
- [32] G. Samorodnitsky and M. S. Taqqu, *Stable Non-Gaussian Random Processes: Stochastic Models with Infinite Variance*. New York: Chapman and Hall, 1994.
- [33] M. D. Stubna and J. Fowler, "An application of the highly optimized tolerance model to electrical blackouts," *Int. J. Bifurc. Chaos*, vol. 13, no. 1, pp. 237–242, 2003.
- [34] D. J. Watts, "A simple model of global cascades on random networks," *Proc. Nat. Acad. Sci.*, vol. 99, no. 9, pp. 5766–5771, 2002.



Benjamin A. Carreras received the Licenciado en Ciencias degree in physics from the University of Barcelona, Barcelona, Spain, in 1965, and the Ph.D. degree in physics from Valencia University, Valencia, Spain, in 1968.

He has been a Researcher and a Professor at the University of Madrid, Madrid, Spain, Glasgow University, Glasgow, U.K., Daresbury Nuclear Physics Laboratory, Warrington, U.K., Junta de Energia Nuclear, Madrid, Spain, and the Institute for Advanced Study, Princeton, NJ. He is now a Corporate Fellow at Oak Ridge National Laboratory, Oak Ridge, TN.

Dr. Carreras is a Fellow of the American Physical Society.



David E. Newman received the B.S. degree in physics and mathematics from the University of Pittsburgh, Pittsburgh, PA in 1983 and the Ph.D. degree in physics from the University of Wisconsin, Madison, in 1993.

He was a Wigner Fellow and Research Scientist at Oak Ridge National Laboratory, Oak Ridge, TN, from 1993 to 1998. In 1998, he joined the Physics Department at the University of Alaska, Fairbanks, where he is now an Associate Professor.



Ian Dobson (M'89–SM'98) received the B.A. degree in mathematics from Cambridge University, Cambridge, U.K., in 1978, and the Ph.D. degree in electrical engineering from Cornell University, Ithaca, NY, 1989.

He was a Systems Analyst for EASAMS Ltd, Frimley, U.K., from 1978 to 1983. In 1989, he joined the University of Wisconsin, Madison, where he is now a Professor in Electrical and Computer Engineering. His current interests are applications of complex systems and nonlinear dynamics, electric power system blackouts and instabilities, and risk analysis of cascading failure.

A. Bruce Poole received the B.S. degree in aerospace/mechanical engineering from the University of Texas in 1968, and the M. A. degree in management from Tusculum College, Greeneville, TN, in 1992.

He was an Engineer and Manager for a variety of manufacturing and utility companies, including Westinghouse Electric Corporation, Houston Lighting and Power Company, and the Tennessee Valley Authority. He worked at Oak Ridge National Laboratory, Oak Ridge, TN, from 1989 to 2000, where he was a Senior Research Staff Member and Program Manager. He presently works for the Federal Energy Regulatory Commission, Washington, DC.